

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**

with type designation(s)

BFOU (i) S3/S7 250 V, BFOU (c) S4/S8 250 V, BFOU (i+c) 250 V

Issued to

Untel Kablolari San. ve Tic. A.S.
Dilovasi, Turkey

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Type	Rated voltage (V)	Temp. class (°C)
BFOU (i) S3/S7 250 V	250	90
BFOU (c) S4/S8 250 V	250	90
BFOU (i+c) 250 V	250	90

Issued at **Hamburg** on **2019-01-18**This Certificate is valid until **2024-01-17**.for **DNV GL**DNV GL local station: **Istanbul**Approval Engineer: **Carsten Hunsalz**

Arne Schaarmann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Type: BFOU (i) S3/S7, BFOU (c) S4/S8 and BFOU (i+c) 250 V

Construction:

Conductors: Tinned, stranded copper class 2 or class 5
Core insulation: Mica-tape + EPR or HEPR
Screen: Copper polyester tape w/ tinned copper drain wire
Bedding: Halogen-free compound
Metal covering: Tinned copper wire braid
Outer sheath: SHF Mud

Number of pairs x conductor cross-section	Overall diameter Approx.	Overall diameter Approx.	Overall diameter Approx.
mm ²	mm	mm	mm
	BFCU(i)	BFCU(c)	BFCU(i+c)
1 x 2 x 0,75	11,1	11,1	
2 x 2 x 0,75	16,7	15,6	17,0
4 x 2 x 0,75	19,1	17,6	19,4
7 x 2 x 0,75	22,5	20,6	22,8
10 x 2 x 0,75	28,3	25,7	28,6
14 x 2 x 0,75	30,8	27,9	31,1
19 x 2 x 0,75	34,5	30,9	34,8
24 x 2 x 0,75	40,8	36,6	41,1
1 x 3 x 0,75	11,6	11,6	
2 x 3 x 0,75	18,1	17,0	18,6
4 x 3 x 0,75	20,9	19,5	21,2
7 x 3 x 0,75	24,9	22,8	25,2
14 x 3 x 0,75	31,5	28,7	31,8
19 x 3 x 0,75	34,7	31,2	35,0
24 x 3 x 0,75	38,9	35,3	39,2
1 x 2 x 1,5	12,5	12,5	
2 x 2 x 1,5	19,0	17,6	19,3
4 x 2 x 1,5	21,9	20,2	22,2
7 x 2 x 1,5	25,9	23,7	26,2
10 x 2 x 1,5	33,2	29,9	33,5
14 x 2 x 1,5	36,5	33,3	37,0
19 x 2 x 1,5	40,7	37,0	41,0
24 x 2 x 1,5	48,0	43,1	48,3
1 x 3 x 1,5	13,1	13,1	
2 x 3 x 1,5	20,8	19,5	21,1

Number of pairs x conductor cross-section	Overall diameter Approx.	Overall diameter Approx.	Overall diameter Approx.
mm ²	mm	mm	mm
	BFCU(i)	BFCU(c)	BFCU(i+c)
4 x 3 x 1,5	24,1	22,4	24,4
7 x 3 x 1,5	28,8	26,4	29,1
10 x 3 x 1,5	37,6	34,0	37,9
14 x 3 x 1,5	40,9	37,4	41,2
19 x 3 x 1,5	45,7	41,4	46,2
24 x 3 x 1,5	53,7	48,8	54,0
1 x 2 x 2,5	13,7	13,7	
2 x 2 x 2,5	20,4	19,1	20,7
4 x 2 x 2,5	23,6	22,0	23,9
7 x 2 x 2,5	28,2	25,9	28,5
10 x 2 x 2,5	36,6	33,5	37,1
14 x 2 x 2,5	40,1	36,4	40,4
19 x 2 x 2,5	44,8	40,5	45,1
24 x 2 x 2,5	52,7	47,7	53,0
1 x 3 x 2,5	14,3	14,3	
2 x 3 x 2,5	22,6	21,0	22,9
4 x 3 x 2,5	26,2	24,2	26,5
7 x 3 x 2,5	31,4	28,9	31,7
10 x 3 x 2,5	41,0	37,6	41,3
14 x 3 x 2,5	45,0	40,9	45,3
19 x 3 x 2,5	50,2	45,7	50,5
24 x 3 x 2,5	59,4	53,7	59,7
1 x 4 x 0,75	11,1	11,1	
1 x 4 x 1,5	12,5	12,5	
1 x 4 x 2,5	13,7	13,7	

Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Instrumentation, communication and control.

Fire resistant. Flame retardant in bunch Cat. A. Halogen free. Low smoke.

Mud resistant.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60331-1/2	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%
NEK TS 606	2009	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	S-types only

Job Id: **262.1-028904-1**
Certificate No: **TAE0000385**

Marking of product

ÜNTEL – BFOU (i) (NEK 606 S3/S7) or BFOU (c) (NEK 606 S4/S8) or BFOU (i+c) – size – 250 V - IEC 60332-3-22 – IEC 60331-1/2

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE